



Michael J. Yox  
Regulatory Affairs Director  
Vogtle 3 & 4

7825 River Road  
Waynesboro, GA 30830  
706-848-6459 tel

**OCT 07 2021**

Docket Nos.: 52-025

ND-21-0872  
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 3  
ITAAC Closure Notification on Completion of ITAAC 3.3.00.07d.iv.b [Index Number 807]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 3.3.00.07d.iv.b [Index Number 807]. This ITAAC verified that for the non-radiologically controlled area of the auxiliary building where spatial separation between Class 1E divisions and Non-Class 1E raceway distance is less than specified, an analysis has been performed and demonstrates that the Class 1E cables will still perform their design function.

The closure process for this ITAAC is based on the guidance described in NEI-08-01, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52" which is endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli Roberts at 706-848-6991.

Respectfully submitted,

A handwritten signature in blue ink that reads "Stucky for Michael J. Yox". The signature is stylized and fluid.

Michael J. Yox  
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 3.3.00.07d.iv.b [Index Number 807]

MJY/CMK/sfr

**To:**

**Southern Nuclear Operating Company/ Georgia Power Company**

Mr. Peter P. Sena III  
Mr. D. L. McKinney  
Mr. H. Nieh  
Mr. M. D. Meier  
Mr. G. Chick  
Mr. S. Stimac  
Mr. P. Martino  
Mr. M. J. Yox  
Mr. A. S. Parton  
Ms. K. A. Roberts  
Ms. J.M. Coleman  
Mr. C. T. Defnall  
Mr. C. E. Morrow  
Mr. K. J. Drudy  
Mr. J. M. Fisher  
Mr. R. L. Beilke  
Mr. S. Leighty  
Ms. A. C. Chamberlain  
Mr. J. C. Haswell  
Document Services RTYPE: VND.LI.L06  
File AR.01.02.06

**cc:**

**Nuclear Regulatory Commission**

Ms. M. Bailey  
Mr. M. King  
Mr. G. Bowman  
Ms. A. Veil  
Mr. C. P. Patel  
Mr. G. J. Khouri  
Mr. C. J. Even  
Mr. B. J. Kemker  
Ms. N. C. Coover  
Mr. C. Welch  
Mr. J. Gaslevic  
Mr. O. Lopez-Santiago  
Mr. G. Armstrong  
Mr. M. Webb  
Mr. T. Fredette  
Mr. C. Santos  
Mr. B. Davis  
Mr. J. Vasquez  
Mr. J. Eargle  
Mr. E. Davidson  
Mr. T. Fanelli  
Ms. K. McCurry  
Mr. J. Parent  
Mr. B. Griman

**Oglethorpe Power Corporation**

Mr. R. B. Brinkman  
Mr. E. Rasmussen

**Municipal Electric Authority of Georgia**

Mr. J. E. Fuller  
Mr. S. M. Jackson

**Dalton Utilities**

Mr. T. Bundros

**Westinghouse Electric Company, LLC**

Dr. L. Oriani  
Mr. D. C. Durham  
Mr. M. M. Corletti  
Mr. Z. S. Harper  
Mr. J. L. Coward

**Other**

Mr. S. W. Kline, *Bechtel Power Corporation*  
Ms. L. Matis, *Tetra Tech NUS, Inc.*  
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*  
Mr. S. Roetger, *Georgia Public Service Commission*  
Mr. R. L. Trokey, *Georgia Public Service Commission*  
Mr. K. C. Greene, *Troutman Sanders*  
Mr. S. Blanton, *Balch Bingham*

U.S. Nuclear Regulatory Commission  
ND-21-0872 Enclosure  
Page 1 of 3

**Southern Nuclear Operating Company  
ND-21-0872  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3  
ITAAC Closure Notification on Completion of ITAAC 3.3.00.07d.iv.b [Index Number 807]**

## **ITAAC Statement**

### **Design Commitment**

7.d) Physical separation is maintained between Class 1E divisions and between Class 1E divisions and non-Class 1E cables.

### **Inspections, Tests, Analyses**

Inspections of the as-built raceways that route Class 1E cables will be performed to confirm that the separation between raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables is consistent with the following:

iv) Separation distances less than those specified above and not run in enclosed raceways or provided with barriers are based on analysis

### **Acceptance Criteria**

Results of the inspection will confirm that the separation between raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables is consistent with the following:

iv.b) For areas in the non-radiologically controlled area of the auxiliary building, a report exists and concludes that separation distances less than those specified above and not provided with enclosed raceways or barriers have been analyzed.

## **ITAAC Determination Basis**

Multiple ITAAC are performed to ensure that physical separation is maintained between Class 1E divisions and between Class 1E divisions and non-Class 1E cables. In accordance with this ITAAC, separation distances for circuits that do not meet the criteria of ITAAC 3.3.00.07d.ii.b [Index 801] or ITAAC 3.3.00.07d.iii.b [Index 804] may be based on analyses. For circuits that have separation distances based on analyses, the subject ITAAC requires inspections to confirm that separation distances have been analyzed. The Class 1E cables and raceways and non-Class 1E cables in the non-radiologically controlled area of the auxiliary building are designed to be appropriately separated in accordance with APP-GW-E1-001 (Reference 1). Installation specifications provided to the constructor identify separation criteria, consistent with the ITAAC commitment.

Class 1E electrical cables and raceways are required to be installed in accordance with design drawings, installation specifications issued for construction and work package requirements. Completed raceway installation, in-progress and completed cable installation, and completed cable terminations are inspected to ensure the separation installation specifications are satisfied. Inspections are performed in accordance with the Construction Quality Verification Program 26139-000-4MP-T81C-N7101 (Reference 2). ITAAC 3.3.00.07d.ii.b [Index 801] will confirm that inspection records are completed to document the satisfactory separation between

raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables.

Cable Separation Report for Analyses (Reference 6) confirmed that the separation between raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables is consistent with the following:

For areas in the non-radiologically controlled area of the auxiliary building, separation distances less than those specified above (i.e. in the COL) and not provided with enclosed raceways or barriers have been analyzed. The analyses performed for this ITAAC are performed in accordance with standard IEEE 384-1981, and demonstrates that the effects of lesser separation for non-Class 1E fiber optic linear heat detection system cables within safety related cable trays and non-fully enclosed raceway/free air cable drops from their raceways to all the PMS cabinets do not impact the ability of Class 1E circuits to perform their safety related functions (References 3 through 5).

Exceptions to the subject ITAAC are not included within the scope of this ITAAC and area addressed within the scope of ITAAC 3.3.00.07d.v.b [Index 810].

References 1 through 6 are available for NRC inspection, as well as the Unit 3 ITAAC 3.3.00.07d.iv.b Completion Package (Reference 7).

#### **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all ITAAC findings and associated corrective actions. This review found no relevant ITAAC findings associated with this ITAAC.

#### **ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC 3.3.00.07d.iv.b was performed for VEGP Unit 3 and that the prescribed acceptance criteria are met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

#### **References (available for NRC inspection)**

1. APP-GW-E1-001, "Electrical Systems Design Criteria"
2. 26139-000-4MP-T81C-N7101, "Bechtel Construction Quality Verification Program"
3. WNA-AR-00516-WAPP, "AP1000 Protection and Safety System Monitoring System Separation Analysis"
4. APP-GW-E0R-006, "IEEE 384 Design Compliance Description"
5. APP-GW-GEF-850316, "Design Evaluations for Compliance with IEEE 384 Spatial Separation"
6. SV3-CSR-ITR-800807 Rev 0, "Unit 3 Cable Separation Report for Analyses"
7. 3.3.00.07d.iv.b-U3-CP-Rev0, "ITAAC Completion Package"